


THIS UNIT IS PRE-SET FOR PLUG N' GO™ OPERATION, ADJUSTMENT IS OPTIONAL.

For full operational details, adjustment and more features of the product, see the DLM System Installation Guide supplied with the LMRC-102 and also available at www.wattstopper.com



LMPC-100

**Digital Lighting Management
PIR Ceiling Mount
Extended Range Occupancy Sensor**

Quick Start Guide

INSTALLATION SHALL BE IN ACCORDANCE WITH ALL APPLICABLE REGULATIONS, LOCAL AND NEC CODES.

Intended for Listed Class 2 DLM Devices.


For Class 2 DLM devices - To be connected to a Class 2 power source only.

For Class 2 Device Wiring Only – Do Not Reclassify and Install as Class 1, or Power and Lighting Wiring.


Wire connections shall be rated suitable for the wire size (lead and building wiring) employed.

- Voltage: 24VDC
- Current Consumption: 7mA
- Power Supply: Watt Stopper/Legrand Room Controllers
- Connection to the DLM Local Network 2 RJ-45 ports
- DLM Local Network Characteristics:
 - Provides low voltage power over Cat 5e cable (LMRJ).
 - Supports up to 24 communicating devices, including 4 LMRC-10x or LMPL-101 max per each DLM Local Network.
 - Free topology up to 1,000ft of low voltage cable.
- Environment For Indoor Use Only
 - Operating Temperature 32° to 131°F (0° to 55°C)
 - Storage Temperature 23° to 176°F (-5° to 80°C)
 - Relative Humidity 5 to 95% (non condensing)
- Patent Pending

SENSOR PLACEMENT (10' MAX. HEIGHT)





○ Sensor



Mount sensor at least 6' away from air supply. Avoid obstacles that block sensor's line-of-sight.


COVERAGE PATTERN

The LMPC-100 provides a 360° coverage pattern. The coverage shown represents maximum coverage for walking motion at a mounting height of 10 feet.




CONNECTIVITY

The illustrations below show examples of free-topology wiring. The LMPC-100 communicates to all other Digital Lighting Management devices connected to the low voltage DLM Local Network, regardless of their position on the DLM Local Network.




MOUNTING

To octagon box:



For applications requiring plenum rating

Through ceiling tile:




No box required in non-plenum rated applications




WARNING: A junction box used for sensor installation must not contain any Class 1, Class 3, or other power or lighting line voltage circuits

FACTORY PRE-SET OPERATION

Sensor Parameters

T-DELAY	Time Delay	20 minutes
	Passive Infrared Sensitivity	90%
W-T	Walk Through	OFF

Load Parameters

	 Load 1	 Loads 2-8 or more**	 Plug Load
ON Mode Operation*	AUTO-ON	MANUAL-ON if switch is connected. AUTO-ON if no switch.	AUTO-ON
Blink Warning	OFF	OFF	OFF
Daylighting	ON	OFF	OFF

* Auto-OFF is enabled according to the sensor Time Delay when a sensor is bound to the load, regardless of whether the load was turned on automatically with occupancy or manually using a switch.

** Max 8 loads using LMRC-100 series room controllers.

TROUBLESHOOTING

Loads do not operate as expected.



WARNING: TO CONNECT A COMPUTER TO THE DLM LOCAL NETWORK USE THE LMCI-100. NEVER CONNECT THE DLM LOCAL NETWORK TO AN ETHERNET PORT - DOING SO MAY DAMAGE COMPUTERS AND OTHER CONNECTED EQUIPMENT.

LEDs don't light, display is off	<ol style="list-style-type: none"> 1. Check to see that the the sensor is connected to the DLM local Network. 2. Check for 24VDC input to the sensor: Plug in a different DLM device at the sensor location. If the device does not power up, 24VDC is not present. <ul style="list-style-type: none"> • Check the high voltage connections to the room controller. • If high voltage connections are good and high voltage is present, recheck DLM local Network connections between the sensor and the room controller.
The wrong lights are controlled	<ol style="list-style-type: none"> 1. Configure the sensor to control the desired lights using the Push n' Learn adjustment procedure.
LEDs turn ON and OFF but load doesn't switch	<ol style="list-style-type: none"> 1. Make sure device is not in PnL. 2. Check load connections to room controller.

WattStopper®

2800 De La Cruz Blvd.
Santa Clara, CA 95050

Phone: 800.879.8585
www.wattstopper.com

10/2014
11435r2

Please Recycle 